



Asbestos Register

Blue Mountains City Council maintains asbestos registers (“registers”) and asbestos management plans (“plans”) relating to each of the buildings owned or occupied by the Council. The registers and plans record information about the existence and location of any known or presumed asbestos containing materials (“ACM”) within those buildings.

The Council’s governing body has adopted the Council’s corporate [asbestos-registers]Asbestos Policy, which is available on our website.

The registers and plans are in two forms. First, the Council maintains a corporate asbestos register and a corporate asbestos management plan. Second, the Council has prepared individual registers and individual plans for each building that contains or may contain ACM. Hardcopies of those individual registers and plans are held in the building concerned.

Whenever work is carried out on a Council building the hardcopy register and the hardcopy plan are each amended by hand, as required. This action ensures that Council employees or contractors who work from time to time within that building have access to accurate information about the ACM that it contains or may contain.

The electronic versions of each of the corporate plans and registers, and of the plans and registers for individual buildings, are periodically updated. However, the key documents are the hardcopy registers and the hardcopy plans for each building which must be inspected before any work is carried out on that building.

NOTES:

- (1) The Council’s electronic registers and plans are valid as dated, and ARE NOT to be relied upon as definitive records and ARE NOT to be used for reference purposes for any construction, demolition, maintenance or any other onsite works. IN ALL CASES, the onsite hardcopy building specific asbestos register and building specific asbestos management plan MUST BE CONSULTED prior to the commencement of physical works on the building concerned. While the electronic versions of the Council’s registers and plans provide guidance concerning the presence or possible presence of ACM it is the onsite hardcopy registers and plans which will remain up to date.
- (2) The Council’s electronic registers and plans relate to Council owned or managed buildings. The electronic registers and plans do not relate to structures (such as picnic shelters, bus shelters and other freestanding structures). Before any work is carried out on such structures the Council’s Hazardous Materials Team (“HMT”) MUST BE CONSULTED. The HMT may be contacted at council@bmcc.nsw.gov.au. The HMT will provide information concerning any ACM that may be present in the structure concerned.

Further information: Further information on safe asbestos management may be obtained by contacting Councils Hazardous Materials Management Team at council@bmcc.nsw.gov.au.



BLUE MOUNTAINS CITY COUNCIL

19/93064

ASBESTOS REGISTER

BLACKHEATH TOWN CENTRE

CAR PARK TOILET BLOCK

15-17 GOVETTS LEAP ROAD

BLACKHEATH



Extract from Asbestos Register AS37272

26 September 2017

Report

ASBESTOS REGISTER

**Blue Mountains City
Council – August 2017**

**Prepared for:
Blue Mountains City
Council**

**Project No.
37272**

**Date:
26-09-17**

The logo for AIRSAFE, featuring the word "AIRSAFE" in white, bold, uppercase letters on a dark blue rectangular background.

93 Beattie Street
Balmain NSW 2041 Australia
T. 02 9555 9034
F. 02 9555 9035
info@airsafe.net.au
www.airsafe.net.au

ABN 36 609 424 946

DISTRIBUTION

Copies	Recipient
2	Richard Kane-White Blue Mountains City Council Strategic Assets Officer Locked Bag 1005 KATOOMBA NSW 2780

© Airsafe OHC Pty Limited [Airsafe]

The information contained in this document is intended for the sole use of the Client identified on the cover sheet for the purpose for which it has been prepared. Airsafe undertakes no duty to or accepts any responsibility for any third party who may rely upon this document.

All rights reserved. No section or element of this document may be removed, reproduced, electronically stored or transmitted in any form without the written permission of Airsafe.

Prepared By:



Ashley McDonald
[SafeWork NSW Licence No LAA 001261]

Reviewed By:



Simon Gorham
Manager

TABLE OF CONTENTS

REFERENCES	8
TERMS AND DEFINITIONS.....	9
1 INTRODUCTION	10
1.1 Authorisation	10
1.2 Scope of Work	10
1.3 Site Description	10
1.4 Methodology	10
1.5 Inaccessible Areas	11
1.6 Limitations	11
2 GENERAL INFORMATION	13
2.1 Effects on Health.....	13
2.2 Asbestos Classification	14
2.2.1 Bonded Asbestos Material	14
2.2.2 Friable Asbestos Material	14
2.3 Control Measures.....	14
3 RESULTS	16
3.1 Asbestos Register	16
3.1.1 – Jubilee Park – 33-65 Clan William Street, Blackheath – Toilet Block (Near Tennis Courts)....	16
3.1.2 – Memorial Park – Gardiner Crescent, Blackheath	17
3.1.3 – Great Western Highway (Level Crossing), Blackheath	18
3.1.4 – Whitely Park – Great Western Highway, Blackheath	18
3.1.5 – Blackheath Glen Tourist Park – Prince Edward Street, Caravan Park.....	19
3.1.6 – Blackheath Swimming Pool – Gardiner Crescent, Blackheath.....	25
3.1.7 – Pulpit Rock Road, Blackheath.....	26
3.1.8 – 15-17 – Govetts Leap Road, Blackheath	27
3.1.9 – Greater Western Highway, Blackheath	28
3.1.10 – 113-125 Greater Western Highway, Blackheath	29
3.1.11 – 33-41 Leichhardt Street, Blackheath	29
3.1.12 – Blaxland Waste Management Facility – 26-30 Attunga Road, Blaxland	30
3.1.13 – Station Street, Blaxland	31
3.1.14 29-39 Mathew Parade, Blaxland	31
3.1.15 – 8 Sir Henry Parade, Faulconbridge	32
3.1.16 – Great Western Highway, Faulconbridge	33
3.1.17 Elizabeth’s Lookout off Barnet Street, Glenbrook	33

The control measures required for identified and presumed ACM should be determined from the risk assessment and should follow the following principles:

- Control Measure 1 -** If the ACM are friable and not in a stable condition, and there is a risk to health from exposure, they should be removed by an asbestos removalist as soon as practicable.
- Control Measure 2 -** If the ACM are friable but are in a stable condition and are accessible, serious consideration should be given to their removal. If the removal is not immediately practicable, short-term control measures, such as sealing and enclosure, May be able to be used until removal is possible.
- Control Measure 3 -** If the ACM are not friable and are in a good, stable condition, minimising disturbance and encapsulation may be appropriate controls.
- Control Measure 4 -** Any remaining ACM should be clearly labeled, where possible, and regularly inspected to ensure they are not deteriorating or otherwise contributing to an unacceptable health risk.

These control measures reflect the following hierarchy of controls:

- 1 - Elimination/removal (most preferred);
- 2 - Isolation/enclosure/sealing;
- 3 - Engineering controls;
- 4 - Safe Work Practices (administrative controls); and
- 5 - Personal Protective Equipment (PPE) (least preferred).

ACM need to be removed before demolition, partial demolition, renovation or refurbishment if they are likely to be disturbed by those works in accordance with the Code of Practice: How to Safely Remove Asbestos [Safe Work Australia, 2011].

3.1.8 – 15-17 – Govetts Leap Road, Blackheath

Location	Material	Sample ID	Sample Status	Photo No.	Asbestos Classification	Condition	Accessibility	Re-inspect	Current Label	Control Measure	Record of Works Undertaken
Asset E00042 – Toilet Block											
Internal											
Men's – Ceiling lining 3135	Fibreboard	37272-12	Negative	-	-	-	-	-	-	-	-
Women's – Ceiling lining 3136	Fibreboard	Similar to 37272-12	Assumed Negative	-	-	-	-	-	-	-	-
Men's – Ceiling lining 3137	Fibreboard	Similar to 37272-12	Assumed Negative	-	-	-	-	-	-	-	-
Men's – Toilet partitions 3138	Fibreboard	37272-13	Negative	-	-	-	-	-	-	-	-

APPENDIX A – ANALYSIS RESULTS



93 Beattie Street Balmain NSW 2041 Australia
T. 02 9555 9034 | F. 02 9555 9035
info@airsafe.net.au | www.airsafe.net.au
93 Beattie Street Balmain NSW 2041 Australia
T. 02 9555 9034 | F. 02 9555 9035
info@airsafe.net.au | www.airsafe.net.au
ABN 36 609 424 946

TEST REPORT

September 26, 2017

Blue Mountains City Council

Locked Bag 1005
KATOOMBA NSW 2780

Your Reference: Blue Mountains City Council - August 2017
Job Number: 37272

Attention: Richard Kane-White

Dear Richard,

In accordance with your instructions, Airsafe tested samples from the above site for asbestos content.

The following samples were processed on the dates indicated.

Samples:	131 Samples
Date of Sample Receipt:	21/08/17 – 28/10/17
Date of Sample Analysis:	21/08/17 – 28/10/17
Date of Preliminary Report Sent:	Not Issued

The results are contained in the following pages of this report.

Should you have any queries regarding this report please contact the undersigned.

Yours faithfully
AIRSAFE OHC PTY LTD

Benjamin Willetts
Approved Identifier and Signatory



Accredited for compliance with ISO/IEC 17025 – Testing.
NATA accredited laboratory 2959.
This report must not be reproduced except in full.
Accredited for compliance with ISO/IEC 17025.
NATA accredited laboratory 2959.
This report must not be reproduced except in full.

PROJECT: Blue Mountains City Council - August 2017

JOB NO: 37272

Sample No	Location/Reference	Sample Description	Asbestos ID - Material
37272 - 1	Asset E00435 – Toilet Block (Near Tennis Courts) – 33-65 Clan William Street, Blackheath – Men’s – Privacy screen	5x5x1mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 - 2	Asset E00409 – Amenities Block – Blackheath tourist park – Perimeter eave linings	20x4x3mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 - 3	Asset E00409 – Amenities Block Switchboard – Blackheath tourist park – Link panel 1 – Conduit paper membrane	70x60x1mm paper membrane	No asbestos detected Organic fibres detected
37272 - 4	Asset E00409 – Amenities Block Storeroom – Blackheath tourist park – Upper wall cladding	15x7x3mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 - 5	Asset E00409 – Amenities Block Storeroom – Blackheath tourist park – Ceiling lining	5x3x1mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 6	Asset E00409 – Amenities Block Men’s bathroom – Blackheath tourist park – Toilet partition walls	15x7x3mm fibreboard fragment	Chrysotile asbestos detected Organic fibres detected
37272 – 7	Asset E00409 – Amenities Block Old boiler room/ Gas room – Blackheath tourist park – Ceiling lining and fragments	15x5x3mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 8	Asset E00440 – Pump House Pump (Green) – Blackheath tourist park – Gasket	1g fibrous gasket fragments	No asbestos detected Organic fibres detected Synthetic mineral fibres detected
37272 - 9	Blackheath Tourist Park – Wattle Cabins Wattle Cabin 4– Fragment on ground	190x5x3mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 - 10	Blackheath Tourist Park – Wattle Cabins Wattle Cabin 4 – Sub floor – Packer	10x5x2mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 11	Blackheath Tourist Park – Wattle Cabins Wattle Cabin 2 – Sub floor – Packer	40x25x5mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 12	Asset E00042 – Toilet Block Men’s – 15-17 Govetts Leap Road, Blackheath – Ceiling lining	5x5x1mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 13	Asset E00042 – Toilet Block Men’s – 15-17 Govetts Leap Road, Blackheath – Toilet partitions	5x5x2mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 14	Asset E00097 Shelter Shed Shelter Shed – 8 Sir Henry Parade, Faulconbridge – Gable	8x5x1mm fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 15	Asset E00564 – Amenities Block (BMCC Staff) Gnomes Shed – Great Western Highway, Glenbrook – Infill panels around front window and door	10x5x2 fibreboard fragment	No asbestos detected Organic fibres detected
37272 – 16	Asset E00564 – Amenities Block (BMCC Staff) Gnomes Shed – Great Western Highway, Glenbrook – Wall cladding around entry door and window	10x2x1mm fibreboard fragment	No asbestos detected Organic fibres detected



Accredited for compliance with ISO/IEC 17025 – Testing.
NATA accredited laboratory 2959.
This report must not be reproduced except in full.

Accredited for compliance with ISO/IEC 17025.
NATA accredited laboratory 2959.
This report must not be reproduced except in full.

APPENDIX C – WARNING SIGNS AND LABELS

